

# Bulletin

## Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOP1-204337-03
Test Date:	2012-01-27
Publication Date:	2017-12-14
Revision Date:	--
Reappraisal Date:	2020-12-14



### MECHANICALLY FASTENED ELASTOPHENE 180 PS DG

### (MARS) MECHANICALLY ATTACHED ROOFING SYSTEM

#### Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	Modified bitumen membrane / Mechanically fastened
Cover board:	N/A
Insulation:	Polyisocyanurate foam insulation board / Loose laid
Vapour barrier:	Self-adhesive membrane
Thermal barrier:	Optional
Decking:	Steel deck

#### Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Experimental Factor)
A	-1,9 kPa (-40 psf)	-1,3 kPa (-27 psf)

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-204337-03

### Products

CAP SHEET MEMBRANE			
TESTED PRODUCT: Membrane composed of a non-woven polyester reinforcement and SBS modified bitumen			
System	Application Method		
A	Torch applied		
ELIGIBLE PRODUCT(S)			
Soprema	Sopralene Flam 250 GR		

BASE SHEET MEMBRANE			
TESTED PRODUCT: Membrane composed of a non-woven polyester reinforcement and SBS modified bitumen			
System	Application Method	Row spacing	Fasteners spacing
A	Mechanically fastened	900 mm (35 in)	610 mm (24 in)
ELIGIBLE PRODUCT(S)			
Soprema	Elastophene 180 PS DG		

COVER BOARD			
TESTED PRODUCT: N/A			

INSULATION (Top Row)			
TESTED PRODUCT: Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced organic felt			
System	Application Method	Fastening Rate	
A	Loose laid	N/A	
ELIGIBLE THICKNESS(ES)			
38 to 102 mm (1½ to 4 in)			
ELIGIBLE PRODUCT(S)			
Soprema	Sopra-ISO		

INSULATION (Bottom Row)			
TESTED PRODUCT: N/A			

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-204337-03

VAPOUR BARRIER			
TESTED PRODUCT: Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen			
System	Fastening Method		Primer
A	Self-adhered		N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopravap'R		

THERMAL BARRIER	
TESTED PRODUCT: Optional	

FASTENERS PULL OUT RESISTANCE		
TESTED PRODUCT(S): #14 roofing fasteners		
System	Screws	Plates
A	#14	Round toothed metal plates of 51 mm (2 in)
FASTENERS MEASURED PULL OUT RESISTANCE		
245 kgf (541 lbf)		
ELIGIBLE PRODUCT(S)		
Soprema	Soprafix #14	Soprafix plate

ADHESIVE	
TESTED PRODUCT: N/A	

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-204337-03

### General Notes

#### 1. Decking:

Tests were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). Tests could be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck to assess eligibility for possible equivalencies.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

#### 2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

#### 3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

#### 4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

#### 5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

#### 6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **EXP** application form, to be studied for approval.

#### 7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

#### 8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.

#### 9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-204337-03

### 10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **EXP**.

### 11. Notice :

**Exp** reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

### 12. Version tracking table:

2017-12-14	First edition

Prepared by:

**EXP** Services Inc.

---

Serge Rochon, P.Eng.  
Provincial Director – Roofing & Building Envelope  
OIQ N° 114865

December 14<sup>th</sup> 2017

---

Date