

Bulletin

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOPI-223880-13
Test Date:	2015-07-02
Publication Date:	2017-12-14
Revision Date:	--
Reappraisal Date:	2020-12-14



MODIFIED BITUMEN SYSTEM, SOPRABASE HD, INSULATION, SOPRAVAP'R ADHERED 12 INCHES

(AARS) ADHESIVE APPLIED ROOFING SYSTEM

Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	N/A
Cover board:	Board composed of a SBS modified bitumen membrane and a wood fiber board / Adhered
Insulation:	Polyisocyanurate foam insulation board / Adhered
Vapour barrier:	Self-adhesive membrane
Thermal barrier:	Optional
Decking:	Steel deck

Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Experimental Factor)
A	-3,6 kPa (-75 psf)	-2,4 kPa (-50 psf)

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-13

Products

CAP SHEET MEMBRANE			
TESTED PRODUCT: Membrane composed of a non-woven polyester reinforcement and SBS modified bitumen.			
System	Application Method		
A	Torch applied		
ELIGIBLE PRODUCT(S)			
Soprema	Sopralene Flam 250 GR		

BASE SHEET MEMBRANE			
TESTED PRODUCT: N/A			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-223880-13

COVER BOARD			
TESTED PRODUCT: Board composed of a SBS modified bitumen membrane and a non-woven polyester reinforcement, factory-laminated to a high-density wood fiber board.			
System	Application Method	Fastening Rate	
A	Adhered	Ribbons at 305 mm (12 in)	
ELIGIBLE THICKNESS(ES)			
12,7 mm (½ in)			
FASTENING METHOD			
Duotack adhesive			
FASTENING PATTERN			
<p>System A</p>			
ELIGIBLE PRODUCT(S)			
Soprema	Soprabase HD		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-13

INSULATION (Top Row)				
TESTED PRODUCT : Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced organic felt.				
System	Application Method		Fastening Rate	
A	Adhered		Ribbons at 305 mm (12 in)	
ELIGIBLE THICKNESS(ES)				
38 to 102 mm (1½ to 4 in)				
FASTENING METHOD				
Duotack adhesive				
FASTENING PATTERN				
<p>System A</p>				
ELIGIBLE PRODUCT(S)				
Soprema	Sopra-ISO			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-223880-13

INSULATION (Bottom Row)	
TESTED PRODUCT: N/A	

VAPOUR BARRIER		
TESTED PRODUCT: Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen.		
System	Fastening Method	Primer
A	Self-adhered	N/A
ELIGIBLE PRODUCT(S)		
Soprema	Sopravap'R	

THERMAL BARRIER	
TESTED PRODUCT: Optional	

FASTENERS	
TESTED PRODUCT(S): N/A	

ADHESIVE		
TESTED PRODUCT: Low-rise, two-component, polyurethane adhesive.		
System	Ribbon's spacing	Primer
A	305 mm (12 in)	N/A
ELIGIBLE PRODUCT(S)		
Soprema	Duotack	

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-223880-13

General Notes

1. Decking:

The tests performed by **EXP** services inc. («**EXP**») were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi).

Equivalency; tests have demonstrated that the self-adhered vapour retarder in the system herein described is suitable for application over properly prepared concrete deck primed with Elastocol Stick or Elastocol Stick Zero.

Tests could be conducted on 4' x 8' x 5/8" standard plywood deck to assess eligibility for possible equivalencies.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **EXP** application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-13

9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **EXP**.

11. Notice :

EXP reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

12. Version tracking table:

2017-12-14	First edition

Prepared by:

EXP Services Inc.

Serge Rochon, P.Eng.
Provincial Director – Roofing & Building Envelope
OIQ N° 114865

December 14th 2017

Date