

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOP1-223880-16
Test Date:	2015-09-22
Publication Date:	2017-05-15
Reappraisal Date:	2020-05-15



COLPLY MEMBRANES FULLY ADHERED WITH SOPRATAACK SYSTEM

(AARS) ADHESIVE APPLIED ROOFING SYSTEM

Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Fully adhered with Soprataack
Base sheet membrane:	Modified bitumen membrane / Fully adhered with Soprataack
Cover board:	Semi-rigid board composed of a fortified asphaltic core 1220 x 1524 x 3,2 mm (4' x 5' x 1/8") / Adhered with Duotack
Insulation:	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4' x 4' x 1 1/2") / Adhered with Duotack
Vapor barrier:	Self-adhering membrane
Thermal barrier:	N/A
Decking:	Steel deck

Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Experimental Factor)
A	-3,6 kPa (-75 psf)	-2,4 kPa (-50 psf)

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-16

Products

CAP SHEET MEMBRANE				
TESTED PRODUCT : Membrane composed of SBS modified bitumen and a composite reinforcement, the surface is protected by granules and the underside is sanded				
System	Application Method			
A	Fully adhered with Sopratack			
ELIGIBLE PRODUCT(S)				
Soprema	Colply Traffic Cap 460			

BASE SHEET MEMBRANE				
TESTED PRODUCT : Membrane composed of SBS modified bitumen and a composite reinforcement, sandblasted on both sides				
System	Application Method	Row spacing	Fasteners spacing	
A	Fully adhered with Sopratack	N/A	N/A	
ELIGIBLE PRODUCT(S)				
Soprema	Colply Base 410			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-16

COVER BOARD				
TESTED PRODUCT : Semi-rigid board composed of a mineral-fortified asphaltic core between two asphalt-saturated glass mat reinforcement				
System	Application Method		Fastening Rate	
A	Adhered with Duotack		Ribbons at 305 mm (12 in)	
ELIGIBLE THICKNESS(ES)				
3,2 mm (1/8 po.)				
FASTENING METHOD				
Duotack adhesive				
FASTENING PATTERN				
<p>System A</p>				
ELIGIBLE PRODUCT(S)				
Soprema	Sopraboard			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-16

INSULATION (Top Row)			
TESTED PRODUCT : Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced felt			
System	Application Method	Fastening Rate	
A	Adhered with Duotack	Ribbons at 305 mm (12 in)	
ELIGIBLE THICKNESS(ES)			
Between 38 to 102 mm (1½ to 4 in)			
FASTENING METHOD			
Duotack adhesive			
FASTENING PATTERN			
<p>System A</p>			
ELIGIBLE PRODUCT(S)			
Soprema	Sopra-ISO		



INSULATION (Bottom Row)	
TESTED PRODUCT : N/A	

FASTENERS PULL OUT RESISTANCE	
TESTED PRODUCT(S) : N/A	

ADHESIVE			
TESTED PRODUCT : Sopratack : Two-component polyurethane adhesive (membrane only)			
TESTED PRODUCT : Duotack : Low-rise, two-component, polyurethane adhesive (else than membrane)			
System	Ribbon's spacing		Primer
A	Sopratack : Full sheet		N/A
	Duotack : 305 mm (12 in)		N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopratack		
	Duotack		

VAPOR BARRIER			
TESTED PRODUCT : Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen			
System	Fastening Method		Primer
A	Self-adhered		N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopravap'R		

THERMAL BARRIER	
TESTED PRODUCT : N/A	

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-16

General Notes

1. Decking:

The tests performed by **exp** services inc. («**exp**») were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi).

Equivalency; tests have demonstrated that the self-adhered vapour retarder in the system herein described is suitable for application over properly prepared concrete deck primed with Elastocol Stick or Elastocol Stick Zero.

Tests could be conducted on 4 'x 8' x 5/8 "standard plywood deck to assess eligibility for possible equivalencies.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-223880-16

9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

11. Notice :

Exp reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

12. Version tracking table :

2017-05-15	First edition

Prepared by:

exp Services Inc.

Serge Rochon, P.Eng.
Provincial Director – Roofing & Building Envelope
OIQ N° 114865

May 15th 2017

Date