

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOP1-231265-06
Test Date:	2016-06-21
Publication Date:	2017-03-01
Reappraisal Date:	2020-03-01



DENSDECK PRIME MECHANICALLY FASTENED SYSTEM (PARS) PARTIALLY ATTACHED (HYBRIDE) ROOFING SYSTEM

Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	Modified bitumen membrane / Torch applied
Cover board:	Moisture and fire resistant gypsum board 1220 x 1220 x 6,4 mm (4' x 4' x 1/4") / Mechanically fastened
Insulation:	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4' x 4' x 1 1/2") / Loose laid
Vapor barrier:	Self-adhering membrane
Thermal barrier:	Optional
Decking:	Steel deck

Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Experimental Factor)
A	-2,9 kPa (-60 psf)	-1,9 kPa (-40 psf)

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-231265-06

Products

CAP SHEET MEMBRANE				
TESTED PRODUCT : Membrane is composed of a non-woven polyester reinforcement and SBS modified bitumen				
System	Application Method			
A	Torch applied			
ELIGIBLE PRODUCT(S)				
Soprema	Sopralene Flam 250 GR			

BASE SHEET MEMBRANE			
TESTED PRODUCT : Membrane is composed of a non-woven polyester reinforcement and SBS modified bitumen			
System	Application Method	Row spacing	Fasteners spacing
A	Torch applied	N/A	N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopralene Flam 180		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-231265-06

COVER BOARD				
TESTED PRODUCT : Moisture and fire resistant gypsum board, covered with non-combustible fiberglass felt and non-asphaltic coating				
System	Application Method		Fastening Rate	
A	Mechanically fastened		4 fasteners / board 1220 x 1220 mm (4' x 4')	
ELIGIBLE THICKNESS(ES)				
Between 6,4 to 15,9 mm (¼" to 5/8")				
FASTENING METHOD				
Screws and plates				
FASTENING PATTERN				
<p>System A</p> <p>The diagram shows a square board with a side length of 1.220m. Four fasteners are positioned in a 2x2 grid. The horizontal distance between the two fasteners in each row is 0.305m. The vertical distance between the two fasteners in each column is 0.305m. The distance from the center of the board to each fastener is 0.305m.</p>				
ELIGIBLE PRODUCT(S)				
Georgia-Pacific	DensDeck Prime			

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-231265-06

INSULATION (Top Row)				
TESTED PRODUCT : Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced felt				
System	Application Method		Fastening Rate	
A	Loose laid		N/A	
ELIGIBLE THICKNESS(ES)				
Between 38 to 102 mm (1½ to 4 in)				
ELIGIBLE PRODUCT(S)				
Soprema	Sopra-ISO			

INSULATION (Bottom Row)				
TESTED PRODUCT : N/A				

FASTENERS PULL OUT RESISTANCE				
TESTED PRODUCT(S) : #12 roofing fasteners				
System	Screws		Plates	
A	#12 x 73,0 mm (2¾ in)		Round plates of 76,0 mm (3 in)	
FASTENERS MEASURED PULL OUT RESISTANCE				
178 kgf (392 lbf)				
ELIGIBLE PRODUCT(S)				
Dekfast (screws)	#12 x 73,0 mm (2¾ in)			
Trufast (plates)	Round metal insulation plates			

ADHESIVE				
TESTED PRODUCT : N/A				

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-231265-06

VAPOR BARRIER				
TESTED PRODUCT : Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen				
System	Fastening Method			Primer
A	Self-adhered			N/A
ELIGIBLE PRODUCT(S)				
Soprema	Sopravap'R			
ELIGIBLE PRODUCT(S) over thermal barrier : N/A				

THERMAL BARRIER				
TESTED PRODUCT : N/A				

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-231265-06

General Notes

1. Decking:

Tests were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). The tests could also be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.

9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-231265-06

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

11. Notice

Exp reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

12. Change(s) included in review(s) :

2017-03-01	First edition

Prepared by:

exp Services Inc.

Serge Rochon, P.Eng.
Provincial Director – Roofing & Building Envelope
OIQ N° 114865

March 1st 2017

Date