

# Bulletin

## Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOP1-DRS-00231265-08-5100
Test Date:	2016-07-14
Publication Date:	2016-12-21
Reappraisal Date:	2019-12-21



### DENSDECK PRIME MECHANICALLY FASTENED AND SOPRASMART BOARD 180 ADHERED (PARS) PARTIALLY ATTACHED (HYBRIDE) ROOFING SYSTEM

#### Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	N/A
Cover board:	Board composed of a SBS modified bitumen membrane with a non-woven polyester reinforcement, factory-laminated on an asphaltic board 914 x 2440 x 5,4 mm (3 ft x 8 ft x 7/32 in) / Adhered
Insulation:	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4 ft x 4 ft x 1½ in) / Adhered
Vapor barrier:	Self-adhering membrane
Thermal barrier:	Fiberglass matfaced, noncombustible, nonstructural, gypsum core board 1220 x 2440 x 12,7 mm (4 ft x 8 ft x ½ in) / Mechanically fastened
Decking:	Steel deck

#### Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Safety Factor)
A	-8,4 kPa (-175 psf)	-5,6 kPa (-117 psf)

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-08-5100

### Products

CAP SHEET MEMBRANE				
TESTED PRODUCT : Membrane is composed of a non-woven polyester reinforcement and SBS modified bitumen				
System	Application Method			
A	Torch applied			
ELIGIBLE PRODUCT(S)				
Soprema	Sopralene Flam 250 GR			

BASE SHEET MEMBRANE				
TESTED PRODUCT : N/A				

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOPI-DRS-00231265-08-5100

COVER BOARD			
TESTED PRODUCT : Board composed of a SBS modified bitumen membrane with a non-woven polyester reinforcement, factory-laminated on an asphaltic board			
System	Application Method	Fastening Rate	
A	Adhered	Ribbons at 102 mm (4 in) o.c.	
ELIGIBLE THICKNESS(ES)			
Between 5,4 to 7,0 mm (7/32 to 9/32 in)			
FASTENING METHOD			
Duotack adhesive			
FASTENING PATTERN			
<p><b>System A</b></p> <p>The diagram shows a rectangular board with a width of 2,440m and a height of 0,914m. Four horizontal ribbons are applied across the width. Each ribbon is 0,151m wide. The ribbons are spaced 0,102m apart from each other. There are 0,049m offsets from the left and right edges of the board to the start and end of the ribbons, respectively.</p>			
ELIGIBLE PRODUCT(S)			
Soprema	Soprasmart Board 180		



INSULATION (Top Row)			
TESTED PRODUCT : Polyisocyanurate foam insulation board laminated on both sides with fibre reinforced felt			
System	Application Method		Fastening Rate
A	Adhered		Ribbons at 102 mm (4 in) o.c.
ELIGIBLE THICKNESS(ES)			
De 25,4 à 101,6 mm (1 à 4 in)			
FASTENING METHOD			
Duotack adhesive			
FASTENING PATTERN			
<p>The diagram shows a square fastening pattern for System A with a side length of 1,220m. It features 10 vertical ribbons. The spacing between the centerlines of the ribbons is 0,102m. The first and last ribbons are offset from the left and right edges by 0,049m. The distance between the centerline of the first ribbon and the centerline of the second ribbon is 0,151m. The distance between the centerline of the second ribbon and the centerline of the third ribbon is 0,253m. This 0,253m spacing is repeated between the centerlines of the 8th and 9th ribbons, and between the centerline of the 9th ribbon and the centerline of the 10th ribbon. The distance between the centerline of the 10th ribbon and the right edge is 0,049m.</p>			
ELIGIBLE PRODUCT(S)			
Soprema	Sopra-ISO		

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-08-5100

INSULATION (Bottom Row)	
TESTED PRODUCT : N/A	

FASTENERS PULL OUT RESISTANCE		
TESTED PRODUCT(S) : #12 roofing fasteners		
System	Screws	Plates
A	#12 x 41,3 mm (1 1/8 in)	Round plates of 76,0 mm (3 in)
FASTENERS MEASURED PULL OUT RESISTANCE		
178 kgf (392 lbf)		
ELIGIBLE PRODUCT(S)		
Dekfast (screws)	#12 x 41,3 mm (1 1/8 in)	
Trufast (plates)	Round metal insulation plates	

ADHESIVE		
TESTED PRODUCT : Low-rise, two-component, polyurethane adhesive		
System	Ribbon's spacing	Primer
A	102 mm (4 in)	N/A
ELIGIBLE PRODUCT(S)		
Soprema	Duotack	

VAPOR BARRIER		
TESTED PRODUCT : Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen		
System	Fastening Method	Primer
A	Self-adhered	Elastocol Stick
ELIGIBLE PRODUCT(S)		
Soprema	Sopravap'R	
ELIGIBLE PRODUCT(S) over thermal barrier		
Soprema	Sopravap'R	



THERMAL BARRIER			
TESTED PRODUCT : High-density gypsum board coated with non-combustible fiberglass felt and non-asphaltic coating			
System	Application Method	Fastening Rate	
A	Mechanically fastened	32 fasteners / board (4 ft x 8 ft)	
ALLOWABLE THICKNESS(ES)			
Between 12,7 to 15,9 mm (½ in into ¾ in)			
FASTENING METHOD			
Screws and plates			
FASTENING PATTERN(S)			
<p><b>System A</b></p>			
ELIGIBLE PRODUCT(S)			
Georgia-Pacific	DensDeck Prime		

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP-DRS-00231265-08-5100

### General Notes

#### 1. **Decking:**

Tests were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). The tests could also be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

#### 2. **Deck equivalency products:**

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

#### 3. **Fasteners Pull Out Resistance:**

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

#### 4. **Adhesive Pull Resistance:**

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

#### 5. **Note on adhesive:**

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

#### 6. **Equivalent products:**

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

#### 7. **Optional components:**

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

#### 8. **Safety factor:**

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed safety factor of 1,5.

#### 9. **Building Wind Load Calculation:**

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without safety factor. It will also compute perimeter's and corner's zone dimensions.

# Roof Testing Laboratory



## Roof System Dynamic Wind Uplift Resistance Results

SOP-DRS-00231265-08-5100

### 10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

### 11. Notice

**Exp** reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

### 12. Change(s) included in review(s) :

2016-12-21	New bulletin format

Prepared by:

**exp** Services Inc.

---

Serge Rochon, P.Eng.  
Provincial Director – Roofing & Building Envelope  
OIQ N° 114865

---

January 10<sup>th</sup>, 2017

Date