

Bulletin

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

File Number:	SOPI-DRS-00231265-10-5100
Test Date:	2016-08-23
Publication Date:	2016-12-21
Reappraisal Date:	2019-12-21



SOPRABOARD MECHANICALLY FASTENED OVER POLYISOCYANURATE INSULATION BOARD

(PARS) PARTIALLY ATTACHED (HYBRIDE) ROOFING SYSTEM

Roofing System Summary

Cap sheet membrane:	Modified bitumen membrane / Torch applied
Base sheet membrane:	Modified bitumen membrane / Torch applied
Cover board:	Semi-rigid board composed of a mineral-fortified asphaltic core 1220 x 2440 x 4,8 mm (4 ft x 8 ft x 3/16 in / Mechanically fastened)
Insulation:	Polyisocyanurate foam insulation board 1220 x 1220 x 38 mm (4 ft x 4 ft x 1½ in / Loose laid)
Vapor barrier:	Self-adhering membrane
Thermal barrier:	N/A
Decking:	Steel deck

Dynamic Uplift Resistance (DUR) as per CSA A123.21

System Designation	Measured Value	Computed Value (To Include 1.5 Safety Factor)
A	-2,6 kPa (-55 psf)	-1,8 kPa (-37 psf)

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-10-5100

Products

CAP SHEET MEMBRANE				
TESTED PRODUCT : Membrane is composed of a non-woven polyester reinforcement and SBS modified bitumen				
System	Application Method			
A	Torch applied			
ELIGIBLE PRODUCT(S)				
Soprema	Sopralene Flam 250 GR			

BASE SHEET MEMBRANE			
TESTED PRODUCT : Membrane composed of a non-woven polyester reinforcement and SBS modified bitumen			
System	Application Method	Row spacing	Fasteners spacing
A	Torch applied	N/A	N/A
ELIGIBLE PRODUCT(S)			
Soprema	Sopralene Flam 180		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-10-5100

COVER BOARD			
TESTED PRODUCT : Semi-rigid board composed of two asphalt-saturated glass mat reinforcement covering a mineral-fortified asphaltic core			
System	Application Method	Fastening Rate	
A	Mechanically fastened	8 fasteners / board (4 ft x 8 ft)	
ELIGIBLE THICKNESS(ES)			
4,8 mm (3/16 in)			
FASTENING METHOD			
Screws and plates			
FASTENING PATTERN			
<p>System A</p> <p>The diagram shows a rectangular board with a total width of 2,440m and a total height of 1,220m. The board is divided into two equal horizontal sections of 1,220m each. There are 8 fasteners arranged in a grid. The horizontal spacing between fasteners is 0,610m, with a 0,152m offset from the left and right edges. The vertical spacing between fasteners is 0,610m, with 0,152m offsets from the top and bottom edges.</p>			
ELIGIBLE PRODUCT(S)			
Soprema	Sopraboard		

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOPI-DRS-00231265-10-5100

INSULATION (Top Row)				
TESTED PRODUCT : Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced felt				
System	Application Method			Fastening Rate
A	Loose laid			N/A
ELIGIBLE THICKNESS(ES)				
Between 25 to 102 mm (1 to 4 in)				
ELIGIBLE PRODUCT(S)				
Soprema	Sopra-ISO			

INSULATION (Bottom Row)				
TESTED PRODUCT : N/A				

FASTENERS PULL OUT RESISTANCE				
TESTED PRODUCT(S) : #12 roofing fasteners				
System	Screws		Plates	
A	#12 x 73,0 mm (2 $\frac{7}{8}$ in)		Hexagonal plates of 73,0 mm (2 $\frac{7}{8}$ in)	
FASTENERS MEASURED PULL OUT RESISTANCE				
178 kgf (392 lbf)				
ELIGIBLE PRODUCT(S)				
Dekfast (screws)	#12 x 73,0 mm (2 $\frac{7}{8}$ in)			
Dekfast (plates)	Hexagonal metal insulation plates			

ADHESIVE				
TESTED PRODUCT : N/A				

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP1-DRS-00231265-10-5100

VAPOR BARRIER				
TESTED PRODUCT : Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen				
System	Fastening Method		Primer	
A	Self-adhered		N/A	
ELIGIBLE PRODUCT(S)				
Soprema	Sopravap'R			
ELIGIBLE PRODUCT(S) over thermal barrier : N/A				

THERMAL BARRIER				
TESTED PRODUCT : N/A				

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP-DRS-00231265-10-5100

General Notes

1. Decking:

Tests were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). The tests could also be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance:

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

Follow all guide lines or supplementary instructions from the manufacturer regarding adhesive application.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on **exp** application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Safety factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed safety factor of 1,5.

9. Building Wind Load Calculation:

An online calculator is available at <http://www.exp.com/fr/rooftesting>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without safety factor. It will also compute perimeter's and corner's zone dimensions.

Roof Testing Laboratory



Roof System Dynamic Wind Uplift Resistance Results

SOP-DRS-00231265-10-5100

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from **exp**.

11. Notice :

Exp reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

12. Change(s) included in review(s) :

First edition	

Prepared by:

exp Services Inc.

Serge Rochon, P.Eng.
Provincial Director – Roofing & Building Envelope
OIQ N° 114865

January 10th, 2017

Date