

Bulletin

Roof Testing Laboratory (ISO 17025)



Roof System Dynamic Wind Uplift Resistance Results

| | |
|---------------------|--------------|
| File number: | MTS-21000105 |
| Test date: | 2021-01-15 |
| Publication date: | 2021-03-12 |
| Last revision date: | N/A |
| Reappraisal date: | 2024-03-12 |



COLPLY MEMBRANES SYSTEM SOPRATAACK ADHERED OVER DENSDECK PRIME (AARS) ADHESIVE APPLIED ROOFING SYSTEM

Tested Roofing System Summary

| | |
|----------------------|--|
| Cap sheet membrane: | Modified bitumen membrane / Adhered |
| Base sheet membrane: | Modified bitumen membrane / Adhered |
| Cover board: | Moisture and fire-resistant gypsum board 4 x 4 ft x ¼ in / Adhered |
| Insulation: | Polyisocyanurate foam insulation board 4 x 4 ft x 1½ in / Adhered |
| Vapour barrier: | Self-adhesive membrane |
| Thermal barrier: | Optional |
| Decking: | Steel deck |

Dynamic Uplift Resistance (DUR) as per CSA A123.21

| System Designation | Measured Value | Computed Value (To Include 1.5 Experimental Factor) |
|--------------------|--------------------|--|
| A | -2,9 kPa (-60 psf) | -1,9 kPa (-40 psf) |

According to the scope of accreditation published on the SCC website
Accredited Laboratory No. 797





Products

| CAP SHEET MEMBRANE | | | | |
|--|---|---------------------|------------------------|-------------------------|
| TESTED PRODUCT: Membrane composed of SBS modified bitumen and a composite reinforcement, the surface is protected by granules and the underside is sanded. | | | | |
| System | Application Method | | | |
| A | Fully adhered with SOPRATAACK (application rate of 33 ft ² /gal or 1,25 L/m ²) | | | |
| ELIGIBLE PRODUCT(S) | | | | |
| SOPREMA | COLPLY TRAFFIC CAP | SOPRALENE 180 FR GR | SOPRASTAR GR | SOPRASTAR FR GR |
| | COLPLY TRAFFIC CAP FR | SOPRALENE 250 GR | SOPRALENE 180 GR | COLPLY TRAFFIC CAP FLEX |
| | COLPLY TRAFFIC CAP FR FLEX | SOPRASTAR GR FLEX | SOPRASTAR GR FR FLEX | |
| SOPREMA System with gravel surfacing | COLPLY BASE 410 FLEX | ELASTOPHENE SANDED | ELASTOPHENE 180 SANDED | SOPRALENE 180 SANDED |
| | COLPLY BASE 410 | | | |
| Note: Follow the manufacturer's recommendations for the definition of the type of gravel / amount of gravel / adhesive rate in which to embed the gravel. | | | | |

| BASE SHEET MEMBRANE | | | | |
|--|---|----------------------|--------------------|------------------------|
| TESTED PRODUCT: Membrane composed of SBS modified bitumen and a composite reinforcement, sanded on both sides. | | | | |
| System | Application Method | Row spacing | Fasteners spacing | |
| A | Fully adhered with SOPRATAACK (application rate of 35 ft ² /gal or 1,17 L/m ²) | N/A | N/A | |
| ELIGIBLE PRODUCT(S) | | | | |
| SOPREMA | COLPLY BASE 410 | COLPLY BASE 410 FLEX | ELASTOPHENE SANDED | ELASTOPHENE 180 SANDED |
| | SOPRALENE 180 SANDED | | | |

Roof Testing Laboratory (ISO 17025)



Roof System Dynamic Wind Uplift Resistance Results

MTS-21000105

| COVER BOARD | | | | |
|---|--------------------|----------|-----------------------|--|
| TESTED PRODUCT: Moisture and fire-resistant gypsum board, covered with non-combustible fiberglass felt and non-asphaltic coating. | | | | |
| System | Application Method | | Fastening Rate | |
| A | Adhered | | Ribbons at 12 in o.c. | |
| ELIGIBLE THICKNESS(ES) | | | | |
| ¼ in | | | | |
| FASTENING METHOD | | | | |
| DUOTACK adhesive | | | | |
| FASTENING PATTERN | | | | |
| <p>The diagram shows a square fastening pattern with a total width and height of 48 inches. Four vertical ribbons are spaced 12 inches apart. There is a 6-inch margin from the left and right edges to the first and last ribbons, respectively.</p> | | | | |
| ELIGIBLE PRODUCT(S) | | | | |
| Georgia-Pacific | DensDeck Prime | DensDeck | | |
| CGC | Securock | | | |

Roof Testing Laboratory (ISO 17025)



Roof System Dynamic Wind Uplift Resistance Results

MTS-21000105

| INSULATION (Top Row) | | | | |
|--|--------------------|----------------|-----------------------|--|
| TESTED PRODUCT: Polyisocyanurate foam insulation board laminated on both sides with fiber reinforced organic felt. | | | | |
| System | Application Method | | Fastening Rate | |
| A | Adhered | | Ribbons at 12 in o.c. | |
| ELIGIBLE THICKNESS(ES) | | | | |
| 1½ in minimum | | | | |
| FASTENING METHOD | | | | |
| DUOTACK adhesive | | | | |
| FASTENING PATTERN | | | | |
| <p>The diagram shows a square panel with a total width of 48 inches and a total height of 48 inches. Five horizontal adhesive ribbons are applied across the panel. The ribbons are spaced 12 inches apart from each other. There is a 6-inch gap between the top ribbon and the top edge of the panel, and a 6-inch gap between the bottom ribbon and the bottom edge of the panel.</p> | | | | |
| ELIGIBLE PRODUCT(S) | | | | |
| SOPREMA | SOPRA-ISO | SOPRA-ISO PLUS | SOPRAROCK DD PLUS | |
| Atlas Roofing Corp. | ACFoam-II | ACFoam-III | ACFoam-IV | |
| Johns Manville | ENRGY 3 | ENRGY 3 CGF | | |
| Hunter Panels | H-Shield | H-Shield CG | | |



| ADDITIONAL INSULATION | |
|--|--|
| TESTED PRODUCT: Optional (same thicknesses and same eligible products as top row). | |

| VAPOUR BARRIER | | | | |
|--|--|-----------------------|--------------------|--|
| TESTED PRODUCT: Self-adhesive membrane composed of a trilaminated woven polyethylene and SBS modified bitumen. | | | | |
| System | Fastening Method | | Primer | |
| A | Self-adhered | | N/A | |
| ELIGIBLE PRODUCT(S) | | | | |
| SOPREMA | SOPRAVAP'R | | | |
| | SOPRAPLY STICK DUO | | | |
| Note: thermal barrier required on steel deck. | | | | |
| SOPREMA | SOPRALENE 180 SP 3.5 | ELASTOPHENE SP 2.2 | | |
| | Note: thermal barrier required on steel deck or wood deck. | | | |
| SOPREMA | SOPRAVAP'R | SOPRALENE STICK | SOPRAPLY STICK DUO | |
| | Note: on wood deck primed according to the manufacturer's recommendations. | | | |

| THERMAL BARRIER | | | | |
|---|---------------------------|----------------------------|--|--|
| TESTED PRODUCT : Optional | | | | |
| ELIGIBLE PRODUCT(S) | | | | |
| Georgia-Pacific | DensDeck (½ in min.) | DensDeck Prime (½ in min.) | | |
| CGC | Securock (½ in min.) | | | |
| Unifix | PermaBase Dek (½ in min.) | | | |
| Application method: adhered or mechanically fastened, the fastening method and rate are under the responsibility of the designer. | | | | |



| FASTENERS |
|------------------------|
| TESTED PRODUCT(S): N/A |

| ADHESIVE | | | |
|--|---|--|--------|
| TESTED PRODUCT: SOPRATAACK (cap and base sheet) : Two-component polyurethane adhesive. | | | |
| TESTED PRODUCT: DUOTACK (cover board and insulation) : Low-rise, two-component, polyurethane adhesive. | | | |
| System | Ribbon's spacing | | Primer |
| A | SOPRATAACK (cap and base sheet) : full surface | | N/A |
| | DUOTACK (cover board and insulation) : 12 in o.c. | | N/A |
| ELIGIBLE PRODUCT(S) | | | |
| SOPREMA | SOPRATAACK | | |
| SOPREMA | DUOTACK | | |



General Notes

1. Decking:

The tests performed by EXP Services inc. « EXP » were performed over a standard roll formed steel deck profile, with a galvanized or aluminum / zinc alloy coating finished, as per ASTM A653, A792, A1008 or CSSBI 10M standards, bearing a thickness of 0.76 mm (0.03 inch) minimum (commonly defined as 22 gauge), corresponding to the ASTM A653M grade SS 230, having a yield point of 230 MPa (33 ksi) and a tensile strength of 310 MPa (45 Ksi). Tests could be performed on concrete deck or standard 4' x 8' x 5/8" plywood deck to assess eligibility for possible equivalencies.

The deck's fastening to the supporting structure must be strong enough to resist wind uplift loads (as defined per NBC requirements).

2. Deck equivalency products:

18 to 22 gage steel deck. Wood or concrete deck which testing gave equivalent or superior uplift resistance than the value specified in the "Fasteners Pull Out Resistance" section.

3. Fasteners Pull Out Resistance:

Testing were conducted in laboratory according to ANSI/SPRI FX-1 2011 standard, over a minimum of 10 test samples on a **Com-Ten** apparatus over steel deck (unless stated otherwise).

4. Adhesive Pull Resistance (when applicable):

Testing were conducted in laboratory over 3 test samples, according to ANSI/SPRI IA-1 2010 standard on a **Com-Ten** apparatus over steel deck (unless stated otherwise) or, according to ASTM D1623 standard over a universal press testing bench, for in-between materials.

5. Note on adhesive:

It is EXP opinion that the application of the adhesive beads in an "S" or straight-line arrangement will not affect the results of this publication. The intention at the job site should be that the glue bead spacings be reasonably distributed on the substrate, in order to come as close as possible to the theoretical patterns when the boards are laid in. Comply with all additional manufacturer's requirements regarding the use of adhesives.

6. Equivalent products:

Only the products listed in this report under eligible products are deemed acceptable as substitute to the tested products. Any other modifications must be requested in written, on EXP application form, to be studied for approval.

7. Optional components:

Any components of this roofing system listed as optional, may be removed from the roof design. Inclusion or exclusion of the said component having no effect on the published dynamic uplift resistance results. (DUR).

8. Experimental factor:

In accordance with CSA A123.21 standard, the published dynamic uplift resistance (DUR) include a computed experimental factor of 1,5.



9. Building Wind Load Calculation:

An online calculator is available at <https://www.nrc-cnrc.gc.ca>.

The calculator will compute, the Wind Load of any given building, for field, perimeter and corners, as per 2015 CNB requirement, without experimental factor. It will also compute perimeter's and corner's zone dimensions.

10. Technical Advisories:

This roof system assessment reports must be read in conjunction with any issued technical advisories from EXP.

11. Notice:

EXP reserves the right to withdraw, without prior notice, any Bulletin of Roof System Dynamic Wind Uplift Resistance Results published and/or make any necessary corrections.

The information in this roofing system report (the "Report") are based on the tests run by EXP of certain combination of materials in a specific and controlled condition to determine the resistance of different roofing systems to wind uplift forces (the "Test"). The results of the Test are subject to certain prerequisite conditions and assumptions made during the Test. In this regard, the Report is for the exclusive use of EXP client for whom the Report was prepared. The information contained in the Report must not be reproduced, used or relied upon in whole or in part without the written consent of EXP. Any third-party user assumes sole responsibility for the use it makes of the information in the Report including but not limited to any decision to purchase roofing material in reliance of the information found in the Report or on the Site. **Exp disclaims all warranties as to the accuracy, completeness or adequacy of the information in the Report or on the Site and accepts no responsibility for damages suffered by any third party arising out of decisions made or actions based on the Report.**

12. Version tracking table:

| | |
|------------|---------------|
| 2021-03-12 | First edition |
| | |

Prepared by:

EXP Services Inc.

Serge Rochon, P. Eng.
O.I.Q. N° : 114865
P.E.O. N° : 100023274
Provincial Manager – Building science and CSA laboratory

2021-03-12

Date